



A Tradition of Stewardship
A Commitment to Service

Department of Public Works

1195 Third Street, Suite 101
Napa, CA 94559-3092
www.countyofnapa.org/publicworks
Main: (707) 253-4351
Fax: (707) 253-4627
Steven E. Lederer
Director of Public Works

September 18, 2020

RE: Steele Canyon Retaining Wall Fire Repair RDS 20-41, ADDENDUM NO.2

Dear Sir/Madam:

Enclosed herein is Addendum Number 2 for the above referenced project. Addendum Number 2 add clarification to questions received from contractors during the bidding process. **All other conditions remain the same.**

ADDENDUM NUMBER 2 includes:

This question and answer page

Q1. What DBE forms are required with the proposal?

Please return forms B1, B2, B3, and B4 with your proposal.

Q2. Does all work need to be completed by no later than October 31?

Work must continue until the wall is repaired, even if the extends beyond October 31. Please also refer to, and be aware of the working days specified in special provision section A and Addendum #1.

Q3. Do excavated spoils that are cleaned out at the base of the shoring or excavated from the wall to make way for the new lagging need to be off hauled and disposed of by the contractor or can they be spread out in the area adjacent to the base of the shoring?

Excess spoils can be placed above the existing wall bench providing they are properly graded, compacted, and BMPS are correctly applied.

END ADDENDUM NUMBER 2

Please complete the Addendum Acknowledgement in the Proposal Form acknowledging receipt of this addendum.

Thank you for your interest in this project. If you have any questions regarding this addendum, please contact James Reese (James.Reese@countyofnapa.org), OR at Napa County Public Works, 1195 Third St. Suite 101, Napa, CA 94559, OR Fax # 707- 299 – 4210. Please include project reference in your correspondence.

Sincerely Yours,
STEVEN E. LEDERER
Director of Public Works

By: 
James Reese P.E.
Associate Engineer