

Town of Yountville



NAPA COUNTY FIRE MARSHAL'S OFFICE TEMPORARY TENTS AND MEMBRANE STRUCTURES FOR COVID-19

PURPOSE

The purpose of this document is to provide the festivities coordinator, owner, lessee and the vendors the necessary information to ensure that tents used are in conformance with California State law. Cal Fire/ Napa County Fire Department (NCFD) provides fire protection, emergency medical, rescue and Fire Marshal Services to the unincorporated areas of Napa County and the Town of Yountville.

SCOPE


Tents, temporary stage canopies and membrane structures shall comply with this document. The provisions of 2019 California Fire Code, Chapter 31, Section 3103 are applicable only to temporary tents and membrane structures. The provisions of California Fire Code, Chapter 31, Section 3104 are applicable to temporary and permanent tents and membrane structures. Other temporary structures shall comply with the California Building Code.

These building standards govern the use of tents, awnings or other fabric enclosures, including membrane (air-supported and air-inflated) structures and places of assemblage, in or under which 10 or more persons may gather for any lawful purpose.

California Code of Regulations, Title 19, Division 1, 303. (a) and (b)

(a) The provisions of California Code of Regulations, Title 19, Division 1, Chapter 2 apply to the sale, offering for sale, manufacture for sale, rental and use of tents within this state.

(b) For building standards relating to tents and membrane structures, see California Code of Regulations, Title 24, Part 9.



Town of Yountville



APPLICABLE CODES AND STANDARDS

Title 24 California Fire Code with local amendments (CFC)

Title 14 Public Resource Code

Title 19 Health and Safety Code California Fire Code Chapter 31

(a) The provisions of California Code of Regulations, Title 19, Division 1, Chapter 2 apply to the sale, offering for sale, manufacture for sale, rental and use of tents within this state.

(b) For building standards relating to tents and membrane structures, see California Code of Regulations, Title 24, Part 9.

PERMIT REQUIRED

A permit is required to use tents for places of assembly, ceremony, fairs and carnivals, worship, cooking, display of vehicles or equipment, competition, or the like. *Exception:* A tent permit is not required for funeral services.

Tents, with or without sides, having an area in excess of 400 square feet shall not be erected, operated or maintained for any purpose without first obtaining a permit and approval from the fire code official.

FIRE DEPARTMENT PERMITS


(A). A permit is required for all tents and membrane structures that exceed 400 square feet in size and have (1) sidewall or more.

(B). A permit is required for all tents and membrane structures that exceed 700 square feet in size that have no sidewalls.

(C). An operational permit is required to conduct an outdoor assembly event where planned attendance exceeds 1,000 persons regardless of the presence of a tent or membrane structure.

BUILDING DEPARTMENT PERMITS

(A). Tents and membrane structures greater than one story shall be designed and constructed to comply with the California Building Code.



Town of Yountville



- (B). Tents and membrane structures greater than 7,500 square feet shall be designed and constructed to comply with the California Building Code.
- (C). Tents and membrane structures that are erected on buildings, balconies, decks or other structures shall be regulated as permanent membrane structures in accordance with the California Building Code.
- (D). Tents and membrane structures with an occupant capacity greater than 1,000 persons shall be designed and constructed to comply with the California Building Code.
- (E). Stages higher than 30 inches.
- (F). All sub-floors greater than 400 square feet and higher than 30 inches.

Note: Tents, canopies and membrane structures that require a permit shall not be erected unless the required permit has been issued. Any company that erects a tent without the required permit will be issued a monetary citation and will be reported to the Contractors State License Board.

PLAN SUBMITAL


Plans shall be submitted to the Town of Yountville's Planning & Building Division. Plans will be submitted within 3 businesses days after submittal.

ITEMS REQUIRED FOR A COMPLETE PLAN SET INCLUDE

CONSTRUCTION DOCUMENTS

A detailed site and floor plan for tents or membrane structures shall be provided with each application for approval. The tent or membrane structure floor plan shall indicate details of the means of egress facilities, seating capacity, arrangement of the seating and location and type of heating and electrical equipment.

Site plan. The construction documents submitted with the application for permit shall be accompanied by a site plan showing to scale the size and location of new construction and existing structures on the site, distances from lot lines, the established street grades and the proposed finished grades and, as applicable, flood hazard areas, floodways, and design flood elevations; and it shall be drawn in accordance with an accurate boundary line survey. In the case of demolition, the site plan shall show construction to be



Town of Yountville



demolished and the location and size of existing structures and construction that are to remain on the site or plot. The building official is authorized to waive or modify the requirement for a site plan when the application for permit is for alteration or repair or when otherwise warranted.

A site plan is also required for any areas located in any existing buildings that will be used for the event. The site plan shall include seating arrangement, exit signs and fire extinguisher locations.

STAGE CANOPIES DOCUMENTS


Temporary stage canopies in excess of 400 square feet shall not be erected, operated or maintained for any purpose without first obtaining approval and a permit from the fire code official and the building official.

REQUIRED DOCUMENTS

Construction documents shall be prepared in accordance with CBC by a registered design professional and include:

- 1) A summary sheet showing the building code used, design criteria, loads and support relations.
- 2) Detailed construction and installation drawings.
- 3) Design calculations.
- 4) Operating limits of the structure explicitly outlined by the registered design professional including environmental conditions and physical forces. (Structure stability documentation)
- 5) Effects of additive elements such as video walls, supported scenery, audio equipment, vertical and horizontal coverings.
- 6) Means for adequate stability including specific requirements for guying and cross-bracing, ground anchors or ballast for different ground conditions. Provide a description of how the tent will be anchored.
- 7) Flame certifications for all sidewalls, tops and fabrics to be used inside the tent.

Designation of responsible part: The owner of the temporary stage canopy shall designate in writing a person to have responsibility for the temporary stage canopy on site. The designated person shall have sufficient knowledge of the construction documents,



Town of Yountville



Manufacturer's recommendations and operations plan to make judgements regarding the structure's safety and coordinate with the fire code official.

Operations plan: The operations plan shall reflect manufacturer's operation guidelines, procedures for environmental monitoring and action to be taken under specified conditions consistent with the construction documents.

INDEPENDENT INSPECTOR

The owner of a temporary stage canopy shall employ a qualified, independent approved agency or individual to inspect the installation of a temporary stage canopy.

LOCATION AND ACCESS:

ACCESS. Fire apparatus access roads shall be provided in accordance with Section 503.

LOCATION. Tents or membrane structures shall not be located within 20 feet of lot lines, buildings, other tents or membrane structures, parked vehicles or internal combustion engines. For the purpose of determining required distances, support ropes and guy wires shall be considered as part of the temporary membrane structure or tent.


[CCR, Title 19, Division 1, § 312] Vehicles necessary to the operation of the establishment shall be parked at least 20 feet from any tent. No other vehicle shall be parked less than 100 feet from any tent except vehicles parked on a public street shall park at least 20 feet from any tent.

REQUIRED ANCHORAGE

Tents or membrane structures and their appurtenances shall be adequately roped, braced and anchored to withstand the elements of weather and prevent against collapsing. Documentation of structural stability shall be furnished to the fire code official on request.

FABRIC CERTIFICATION AND LABELING FOR LARGE TENTS

Before a permit is granted, the owner or agent shall file with the fire department a Certificate of Flame Resistance issued by a State Fire Marshal approved testing laboratory or by a State Fire Marshal approved applicator of a State Fire Marshal approved flame retardant chemical or by a State Fire Marshal approved manufacturer certifying that the tent(s) and their appurtenances; sidewalls, drops, tarpaulins, floor coverings, bunting and combustible decorative materials and effects, including hay and sawdust when used on



Town of Yountville



floors, has been treated in an approved manner or is made of State Fire Marshal approved and listed inherently flame resistant fabric and that the flame retardant treatment is effective for the use period specified by the permit. Tent tops and sidewalls shall have a permanently affixed label by a California State Fire Marshal licensed applicator or manufacturer bearing the following information:

- 1) The Seal of Registration
- 2) If treated fabric, the name and registration number of the approved application concern and approved chemical used, and the date of treatment.
- 3) If registered fabric, the trade name and registration number of the approved fabric, and the date of production.

LABEL

Tents shall have a permanently affixed label bearing the identification of size and fabric or material type.

REQUIRED LABELS



Certificate of Flame Resistance		
REGISTERED FABRIC OR CONCRETE NUMBER	PAID BY	Date issued or manufactured
This is to certify that the materials described on the reverse side hereof have been flame-retardant treated (or are inherently non-flammable).		
FOR	ADDRESS	
CITY	STATE	
Certification is hereby made that: (Check "a" or "b")		
<input type="checkbox"/>	(a) The articles described on the reverse side of this Certificate have been treated with a flame-retardant chemical registered and approved by the State Fire Marshal and that the application of said chemical was done in accordance with the laws of the State of California and the Rules and Regulations of the State Fire Marshal.	
	Name of chemical used	Chem. Reg. No.
	Method of application	
<input type="checkbox"/>	(b) The articles described on the reverse side hereof are made from a flame-retardant fabric or material registered and approved by the State Fire Marshal for such use.	
	Trade name of flame-retardant fabric or material used	Reg. No.
The Flame Retardant Process Used _____ Be Removed By Washing		
Name of Applicant or Production Submitter		By Name Title


24 pt. type
WARNING
16 pt. type
**KEEP ALL FLAME
AND HEAT SOURCES
AWAY FROM THIS
TENT FABRIC**

12 pt. type
This tent is made with flame-resistant fabric which meets CPAI-84 specifications. It is not fire proof. The fabric will burn if left in continuous contact with any flame source.

The application of any foreign substance to the tent fabric may render the flame resistant properties ineffective.

REQUIRED CERTIFICATE FABRIC CERTIFICATION AND LABELING FOR SMALL TENTS

Small tents shall have a permanently affixed label bearing the following information as specified in CPAI-84.



Town of Yountville



- 1) Certification- A statement that the materials used in the manufacture of the item meet the flame resistance requirements of CPAI-84.
- 2) Manufacturer Identification.
- 3) Warning label stating the following: Warning, Keep all flame and heat sources away from this tent fabric. This tent is made with flame resistant fabric which meets CPAI-84 specifications. It is not fireproof. The fabric will burn if left in continuous contact with any flame source. The application of any foreign substance to the tent fabric may render the flame resistant properties ineffective.


COMBUSTIBLE MATERIALS FOR ASSEMBLY OCCUPANCIES

No person shall use or display any combustible decorations such as hay, straw, shavings, dry vegetation, large dimensions of fabric, for example curtains, tablecloths and other decorations or visual effects, or any other hazard, without first treating said material with a State Fire Marshal approved fire retardant chemical. All treated material shall have proof of treatment affixed to it in accordance with the State Fire Marshal's regulations. A 3" x 3" sample of the decorative fabric shall be submitted for acceptance, at least 72 hours in advanced, and accompanied by a Certificate of Flame Resistance. *Exception:* Materials necessary for the daily feeding and care of animals.

FIRE PROTECTION

Portable fire extinguishers shall be located in conspicuous locations where they will be readily accessible and immediately available for use along normal paths of travel. Portable fire extinguishers shall not be obstructed or obscured from view and shall be provided with a locating sign when deemed necessary by the authority having jurisdiction.

- 1) One Class 2A-10BC fire extinguisher shall be provided in every tent having a floor area between 500 square feet and 1000 square feet. One additional fire extinguisher shall be provided for each additional 2000 square feet or fraction thereof or at the discretion of the authority having jurisdiction. [Title 19]
- 2) Tents having a capacity of 1000 or more persons shall be protected on each of the long sides with fire hose lines of at least 1 ½ inch internal diameter and of sufficient length to reach either end of the tent. The water supply shall be either from the public water mains or from tanks having a capacity of not less than 500 gallons. There shall be at least 65 pounds of flowing pressure at the nozzle of the hose line when a ½ inch tip is used. [Title 19]



Town of Yountville



- 3) Any booth or tent using combustible or flammable liquids must have a U.L. listed fire extinguisher with a rating of not less than 2A:10B:C, be fully charged, bearing the California State Fire Marshal label and be placed in an accessible location near the exit of the structure. [Title 19, 2013 CFC]
- 4) Every tent which prepares or serves heated food shall be equipped with a 2A:10B:C fire extinguisher bearing a current California State Fire Marshal service tag, and be fully charged, and placed in an accessible location near the exit of the structure. Or a new fire extinguisher, minimum five (5) pounds, with the sales receipt taped to the side of it for visual inspection. [Title 19, AHJ]
- 5) At least one Class 10BC fire extinguisher shall be provided with each generator or transformer. [Title 19]

FIRE PROTECTION FOR COOKING

A K-rated fire extinguisher shall be provided for all cooking applications utilizing grease or combustible cooking media. (vegetable or animal oils or fats)

FIRE SAFETY PERSONNEL


The owners or operators of any tent used as a place of assemblage shall provide at least one qualified fire safety person in every tent having a capacity of 500 persons and one additional qualified person for each 1,000 additional persons or fraction thereof. Such persons shall be on duty in the tent at all times when the tent is open to the public. They shall be proficient in the handling of fire extinguishers and equipment and shall be familiar with the fire and panic safety regulations. The individual designated under this section shall meet the approval of the fire authority having jurisdiction.

STANDY PERSONNEL

When in the opinion of the fire code official, it is essential for public safety in a tent due to the use or the nature of the activity the owner, agent or lessee shall employ one or more qualified persons as required and approved to remain on duty during the times such places are open to the public and or activities are being conducted. Standby personnel shall keep diligent watch for fires and take prompt measures for extinguishment, assist in evacuation, and call 9-1-1.

CROWD MANAGERS

There shall be trained crowd managers or crowd managers/supervisors at a ratio of one crowd manager/supervisor for every 250 occupants.



Town of Yountville



ABATEMENT OF FIRE AND PANIC HAZARDS

Any condition that presents a fire hazard, would contribute to the rapid spread of fire, interfere with the rapid exit of persons from the tents, or interfere with or delay the extinguishment of a fire, shall be immediately corrected as ordered by the enforcing authority.

HOUSEKEEPING AND COMBUSTIBLE VEGETATION REMOVAL

The areas within and adjacent to the tent shall be maintained clear of all combustible materials and vegetation that could create a fire hazard within 30 feet. Combustible trash shall be removed at least once per day during the period that the tent is occupied by the public. The accumulation of combustible trash in the form of papers, boxes, etc., when stored next to open flame or hot cooking devices present a tremendous fire hazard. Hot oil can ignite other items and can cause serious and/or lethal burns. Use common sense and pay attention! Do not block your exits - always leave a clear and open path to the outside when you are working in a portable structure.

WEED ABATEMENT AND VEGETATION REMOVAL

Vegetation, weeds, hay, straw trash, flammable materials and the like, shall be removed and stored a minimum of 50 feet from a tent.

COMBUSTIBLE WASTE MATERIAL


The floor surface inside tents and the grounds outside and within 30 feet in perimeter shall be kept free of combustible waste and other combustible materials that could create a fire hazard.

CLEARANCE

There shall be a minimum clearance of at least 3 feet between the fabric envelope and all contents located inside membrane structures.

SMOKING

Smoking shall not be permitted in tents or in any areas adjacent to where hay or other highly flammable materials are kept. Approved "NO SMOKING OR VAPING" signs shall be conspicuously posted in all tents open to the public and wherever otherwise specified by the enforcing authority.



Town of Yountville



OPEN FLAMES


Open flame or other devices (candles, torches, and the like) emitting flame, fire or heat, lanterns or any flammable or combustible liquid, gas, charcoal or other cooking device, shall not be permitted inside or located within 20 feet of a tent unless approved by the fire code official.

FIREWORKS

Fireworks shall not be used within 100 feet of tents or membrane structures.

HEATING AND COOKING EQUIPMENT

- 1) Electrical heating and cooking equipment shall comply with the California Electrical Code.
- 2) Open flame or other devices emitting flame, fire or heat or any flammable or combustible liquids, gas, charcoal or other cooking device or any other unapproved devices shall not be permitted inside or located within 20 feet of the tent while open to the public unless approved by the fire code official.
- 3) Heating and cooking equipment shall not be located within 10 feet of exits or combustible materials.
- 4) Tents with sidewalls or drops where cooking is performed shall be separated from other tents by a minimum of 20 feet.
- 5) Outdoor cooking that produces sparks or grease laden vapors shall not be performed within 20 feet of a tent.
- 6) Solid flammables, butane or other similar devices which do not pose an ignition hazard shall be approved for cooking demonstrations and warming of food. Solid fuel cooking shall be isolated from contact with the public by physical guards, fencing, or enclosure.
- 7) Electrical heating and cooking equipment shall be approved by the fire code official.
- 8) All commercial cooking equipment located inside of a trailer or fully enclosed constructed booth made of permanent materials shall be provided with an approved automatic fire extinguishing system which is U.L. 300 compliant, bearing an approved service label as certified by the Office of the State Fire Marshal.
- 9) All barbeque cooking shall be conducted only outside of tents. Gas-fired barbeque shall be placed a minimum of 20 feet from any structure, overhang or fabric.



Town of Yountville



10) Solid fuel cooking shall be a minimum of 20 feet from any structure, overhang or fabric.

11) No combustible or flammable liquids shall be heated directly on any heater or cooking appliance. Substance such as candle wax shall be melted in containers set in boiling water (double boiler) to keep the wax from reaching its ignition temperature.

12) All deep fryers and other cooking appliances (i.e. pots, pans, woks, etc.) with a capacity of one (1) gallon (4 quarts) of cooking oil or more shall be kept outside of tents, trailers, or the like and placed a minimum of 20 feet away, or shall be located under a commercial kitchen hood provided with a U.L. 300 compliant fire extinguishing system bearing an approved service label as certified by the Office of the State Fire Marshal.

COMPRESSED GAS CYLINDERS

1) Propane fired devices must be approved by Underwriters Laboratories (UL) or by the American Gas Association (AGA). These labels must be accessible for inspection.

2) Liquefied Petroleum (LP) gas containers of 500 gallons or less shall be located outside of the tent with a minimum separation distance of least 10 feet between container and structure and shall have the safety release valve pointed away from the tent.

3) Liquefied Petroleum (LP) gas containers of 500 gallons or more shall be located outside of the tent with a minimum separation distance of least 25 feet between container and structure and shall have the safety release valve pointed away from the tent.

4) All cylinders shall be stored in an upright position, adequately secured in place and protected to prevent accidental tip-over, tampering, unauthorized movement and damage by vehicles or other hazards.


5) Cylinders not in use shall be capped.

6) All compressed gas cylinders in use shall be equipped with individual regulators with approved hose and appliances.

7) All L.P. gas cylinders shall be within current hydrostatic test date, (no more than 12 years from date of manufacture, or no more than five (5) years from last hydrostatic test).

FLAMMABLE AND COMBUSTIBLE LIQUID STORAGE

Flammable-liquid-fueled equipment shall not be used in tents. Storage of flammable and combustible liquids shall be stored outside in an approved manner and not less than 50 feet from tents. Refueling shall be performed in an approved location and not less than 20 feet from tents



Town of Yountville



ELECTRICAL

Electrical equipment and installations shall comply with the California Electrical Code.

Some temporary lighting may require an electrical permit. Contact the City of Elk Grove Building Department for requirements. Before an extension cord can be used with a portable appliance all the following must be met:


- 1) Extension cords shall be plugged directly into an approved receptacle.
- 2) Extension cords shall serve only one appliance or fixture.
- 3) Extension cords shall not exceed 75 feet in length and be no smaller than 16 gauge wire.
- 4) The current capacity of the cord shall not be less than the rated capacity of the appliance or fixture.
- 5) The extension cord is maintained in good repair, without splices, deterioration or damage.
- 6) The extension cord shall be of the grounded type when servicing grounded appliances or fixtures.
- 7) If an extension cord has to go across a traffic area, then an approved traffic pad shall be used.
- 8) All extension cords shall be secured to prevent a tripping hazard.
- 9) Extension cords shall not be connected in series.

INTERNAL COMBUSTION POWER SOURCES- GENERATORS AND SIMILAR EQUIPMENT

Generators and other internal combustion power sources shall be separated from tents by a minimum of 20 feet and shall be isolated from contact with the public by fencing, enclosure or other approved means. All tripping hazards shall be secured.

DISPLAY OF MOTOR VEHICLES

Batteries shall be disconnected in an appropriate manner. Vehicles shall not be fueled or defueled within and tent. Fuel tanks shall not exceed one-quarter of the tank capacity or 5 gallons whichever is less. Fuel systems shall be inspected for leaks and fuel tank openings shall be sealed to prevent the escape of vapors.



Town of Yountville



SEATING ARRANGEMENTS

Where chairs and/or tables are used, the arrangement shall be such to provide aisles 44” wide where obstructions are placed on both sides.

With standard row seating, the spacing of chairs shall provide a space of not less than 12” from the back of one chair to the front of the most forward projection of the chair immediately behind. The rows of chairs shall be spaced not less than 33” back to back.

There shall be no more than 14 seats in any row of seats with aisles at each end. All loose seats, folding chairs or similar seating facilities that are not fixed to the floor shall be bonded together in groups of not less than three. EXCEPTION: When not more than 200 such seats, chairs or facilities are provided, bonding thereof may be deleted. [CCR Title 19 Division 1]


AISLES

The width of aisles without fixed seating shall be a minimum of 44 inches in seating areas and be progressively increased in width to provide not less than one foot of aisle width for each 50 persons served by the aisle. Arrangement of aisles shall be subject to approval by the fire code official.

EXITING AND OCCUPANT LOAD

Tents shall have proper exiting in place. Each tent shall at least one exit and no less than the number of exits as indicated in the table below. Number of exits are based on the size of the tent, number of walls (sides) and occupant load. Maximum occupant load signs shall be posted when required by the fire code official.

Exits shall be spaced at approximately equal intervals around the perimeter of the tent and shall be located such that all points within the tent are within 100 feet or less from an exit.



Town of Yountville



OCCUPANT LOAD	MINIMUM NUMBER OF MEANS OF EGRESS	MINIMUM WIDTH OF EACH MEANS OF EGRESS (inches)	
		Tent	Membrane
10 to 199	2	72	36
200 to 499	3	72	72
500 to 999	4	96	72
1,000 to 1,999	5	120	96
2,000 to 2,999	6	120	96
Over 3,000 ^a	7	120	96

For SI: 1 inch = 25.4 mm.

a. When the occupant load exceeds 3,000, the total width of means of egress (in inches) shall not be less than the total occupant load multiplied by 0.2 inches per person.


EXIT SIGNS

otherwise necessary to indicate clearly the direction of egress where the exit serves an occupant load of 50 or more.

Exit signs shall be either listed and labeled in accordance with UL 924 as the internally illuminated type and used in accordance with the listing or shall be externally illuminated by luminaires supplied in either of the following manners:

- 1) Two separate circuits, one of which shall be separate from all other circuits, for occupant loads of 300 or less.
- 2) Two separate sources of power, one of which shall be an approved emergency system, shall be provided where the occupant load exceeds 300. Emergency systems shall be supplied from storage batteries or from the on-site generator set, and the system shall be installed in accordance with the *California Electrical Code*. The emergency system provided shall have a minimum duration of 90 minutes when operated at full design demand.

Exits shall be clearly marked with exit signs in tents having an occupant load of 50 or more. Illuminated exit signs shall be installed at all required exit doorways for occupant



Town of Yountville



loads of 51 to 299 person or as determined by the fire code official. Illuminated exit signs shall be an approved self-luminous type or shall be internally illuminated. Two separate circuits are required, one of which separate from all other circuits. For occupant loads of 300 or more, two separate sources of power, one of which is an emergency system consisting of onsite storage batteries or and on site generator, shall be provided.

EMERGENCY LIGHTING

Means of egress illumination shall be provided whenever the tent is occupied. An intensity of not less than one foot-candle at floor level is required. Fixtures shall be supplied form a separate circuit or source of power. In the event of power failure an emergency electrical system shall automatically illuminate the means of egress system.

PARKING OF VEHICLES

Vehicles necessary to the operation of the establishment and parked on a public street shall be parked at least 20 feet from any tent. No other vehicles shall be parked less than 100 feet from any tent.

INSPECTIONS

Provide a minimum of 72 hours notification for weekday inspections.
Provide a minimum of one (1) weeks' notice for weekend inspections.
Contact Napa County Building Dept. at 707-253-4416
Contact Napa County Fire Marshal's Office at 707-299-1464. Info

INSPECTION PROCEDURE

The person that was issued the permit is required to be on-site along with two copies of the permit and a copy of the approved set of plans. Napa County Fire will conduct an inspection to determine compliance with these requirements. Therefore, the inspection will be conducted once the tent or membrane structure, all furnishings and all equipment has been installed. In the event fire and life safety violations are found, the responsible person will be given one opportunity for compliance. Failure to adhere to these requirements may result in closure of the respective operation. It shall be the responsibility of the promoter to insure vendors are aware of these regulations. The property owner or representative will be required to sign the tent permit for all events.