



A Tradition of Stewardship
A Commitment to Service

Department of Public Works

1195 Third Street, Suite 101
Napa, CA 94559-3092
www.countyofnapa.org/publicworks

Main: (707) 253-4351
Fax: (707) 253-4627

Steven E. Lederer
Director

August 11, 2022

**Re: SOUTH CAMPUS CHILD WELFARE SERVICES SAFETY AND SECURITY
IMPROVEMENT PROJECT, PW 21-28**

Dear Sir/Madam,

Enclosed herewithin is Addendum Number 3 for the above referenced project. This Addendum Number 3 forms a part of the contract documents, modifies the original specifications and drawings and shall be acknowledged in the Addendum Acknowledgement page of the bid proposal forms. All other conditions remain the same.

ADDENDUM NUMBER 3

ITEM 1: Coversheet and Notice to Contractors Statements

Disregard:

Contractor shall possess a Class A or B license at the time of contract award, registered with the State of California Department of Industrial Relationat at the time of bid opening.

Replace with:

At a minimum, Contractor shall possess a Class B license at the time of contract award, registered with the State of California Department of Industrial Relationat at the time of bid opening.

ITEM 2: Special Provisions, Section B, General Provisions, Subsection (I), Working Hours Requirements

Disregard:

Normal work week shall be Monday through Friday 7:00 am to 4 pm unless otherwise approved by Owner

Replace with:

Lobby Area:

Work shall be performed after hours or as approved and shall be coordinated with owner 72 hours prior to work to be performed.

Playground area:

Work shall be performed 7:00 am to 4:00 pm or as approved and shall be coordinated with owner 72 hours prior to work to be performed.

Contractor shall provide a construction schedule summarizing all work to be performed at the pre-construction meeting and prior to mobilization.

ITEM 3: Special Provisions, Section A, General Conditions, Section 11, Proposal Requirements and Conditions, (a) Examination of Site

Disregard:

Reference to 'Site Visit Affidavit'.

This document is not included in the bid documents. Mandatory site visits were conducted which required bidders to sign-in/out to document attendance.

ITEM 4: Questions from Bidders:

Q1): Can you please provide a specification for the security window? Is there a specific manufacturer? Is there a specific Glass/poly required?

A1): Basis of design for the Transaction Window is:

Manuf: Covenant Security Equipment

Make: Custom – QS-TW2-4848-NBR-C

Q2): I've reviewed the attachments and I didn't see any Specs nor an actual window dimension for the Transaction Window. I will need clarification on:

A2):

Finishes? Frame is clear anodized alum, base stainless steel

Window Size? Per window type W1, A-401 (48" x 48")

Bullet Resistant or Not? No

With Transaction Tray or Not? No transaction tray – just flat transaction ledge.

Glass thickness? ¼" Tempered

With lock or without? 12" x 4" slide up with lock option

Standard Speaker Hole? Natural Voice Port speak thru

END OF ADDENDUM NUMBER 3

Thank you for your interest in this project. If you have any questions relating to this correspondence please submit in writing to John Vicencio by email at John.Vicencio@countyofnapa.org or Napa County Public Works, 1195 Third Street Suite 101, Napa Ca. 94559.

Very Truly Yours,

STEVEN E. LEDERER
Director of Public Works

by: 

John J. Vicencio, P.E.
Associate Engineer