



A Tradition of Stewardship  
A Commitment to Service

# PRIVATE POOL SAFETY NOTICE

## PROPERTY OWNER

Owner Name: _____			
Site Address: _____	City: _____	State: _____	Zip: _____
Mailing Address: _____	City: _____	State: _____	Zip: _____
Phone: _____	Fax: _____	APN#	<input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/>

## CONTRACTOR INFORMATION

Company Name: _____	License #: _____	Class: _____	Expires: _____
Mailing Address: _____	City: _____	State: _____	Zip: _____
Email: _____	Contact Person: _____		

I/We have reach(ed) a contractual agreement with the above listed contractor to construct a swimming pool at the above property. Furthermore, I have been advised by our pool contractor of the state requirements of the "Swimming Pool Safety Act" and agree to install at least two (2) of the following safety features: (115922 Health & Safety Code Amendment: Assembly Bill 2977 Chapter 478 Section 1)

**(Check Your Proposed Methods)**

- (1) The pool shall be isolated from access to a home by an enclosure that meets the following requirements:  
An enclosure shall have all of the following characteristics:
  - (a) Any access gates through the enclosure open away from the swimming pool, and are self-closing with a self-latching device placed no lower than 60 inches above the ground.
  - (b) A minimum height of 60 inches.
  - (c) A maximum vertical clearance from the ground to the bottom of the enclosure of two inches.
  - (d) Gaps or voids, if any, do not allow passage of a sphere equal to or greater than four inches in diameter.
  - (e) An outside surface free of protrusions, cavities, or other physical characteristics that would serve as handholds or footholds that could enable a child below the age of five years to climb over.
- (2) The pool shall be equipped with a removable mesh pool fencing that meets American Society for Testing and Materials (ASTM) Specifications F 2286 standards in conjunction with a gate that is self-closing and self-latching and can accommodate a key lockable device.
- (3) The pool shall be equipped with an approved safety pool cover that meets all requirements of the ASTM Specifications F1346. Indicate the location of the auto cover switch on your plans.
- (4) The residence shall be equipped with exit alarms on those doors providing direct access to the pool. The alarm shall sound continuously for a minimum of 30 seconds within seven seconds after the door and its screen, if present, are opened, and be capable of providing a sound pressure level of not less than 85 dBA when measured indoors at 10 ft. The alarm shall automatically reset under all conditions. It shall be equipped with a manual means to temporarily deactivate the alarm for a single opening. Such deactivation shall last no longer than 15 seconds. The deactivation switch shall be located at least 54 inches above the threshold of the door.
- (5) All doors providing direct access from the home to the swimming pool shall be equipped with a self-closing, self-latching device with a release mechanism placed no lower 54 inches above the floor.
- (6) Swimming pool alarms that, when placed in pools, will sound upon detection of accidental or unauthorized entrance into the water. These pool alarms shall meet and be independently certified to the ASTM Standard F 2208 which includes surface motion, pressure, sonar, laser, and infrared type alarms.

I/We further understand that the required safety feature(s) must be specified on the building plans and be installed prior to the pre-plaster inspection.

Owner's Signature: \_\_\_\_\_ Date: \_\_\_\_\_