

SWIMMING POOL/SPA DAILY OPERATING RECORDS

**Maintain records for one year minimum; provide records at time of inspection or whenever requested

MONTH - _____ OPERATOR - _____

Date	Chlorine		PH	Chemicals Added				Backwash	Filter Cleaned	Other
	a.m.	p.m.		Soda ash	Acid	Chlor	Other			
1										
2										
3										
4										
5										
6										
7										
8										
9										
10										
11										
12										
13										
14										
15										
16										
17										
18										
19										
20										
21										
22										
23										
24										
25										
26										
27										
28										
29										
30										
31										

CYANURIC ACID _____ ppm (maximum allowed is 100 ppm; test at least once monthly)

Operating Notes: pH range: 7.2 – 8.0 (Ideal is 7.4 – 7.6); Free chlorine minimum: 1.0 if using unstabilized chlorine and 1.5 if using stabilized chlorine; Someone must maintain and test pool every day it is open for use.