



A Tradition of Stewardship  
A Commitment to Service

Planning, Building & Environmental Services

1195 Third Street, Suite 210  
Napa, CA 94559  
www.countyofnapa.org

David Morrison  
Director

### WATERTIGHT TEST CERTIFICATION

Complete this form and return it to:

Napa County Planning, Building and Environmental Services  
1195 Third Street, Suite 210  
Napa, CA 94559

This certification is for an IAPMO listed septic/sump tank watertight test. The septic system designer of record must complete this certification.

Assessor's Parcel Number (APN): \_\_\_\_\_

Site Owner: \_\_\_\_\_

Site Address: \_\_\_\_\_

Septic System Permit Number: \_\_\_\_\_

Septic Tank Manufacturer & Size: \_\_\_\_\_ Test date \_\_\_\_\_

Recirc. Tank Manufacturer & Size: \_\_\_\_\_ Test date \_\_\_\_\_

Sump Tank Manufacturer & Size: \_\_\_\_\_ Test date \_\_\_\_\_

I, the undersigned, declare under penalty of perjury that all septic/recirc./sump tanks are installed and tested to be watertight in conformance with the Napa County Planning, Building and Environmental Services watertight test protocol. (See below)

Executed this \_\_\_\_\_ day of \_\_\_\_\_, 20\_\_\_\_ in Napa County, California.

Signature: \_\_\_\_\_

Print Name: \_\_\_\_\_

Napa County Planning, Building and Environmental Services watertight testing protocol:  
Septic/Recirc./Sump tank(s) shall be filled with water to two (2) inches above the tank and riser connection (or highest riser connection). Let concrete tanks stand for twenty-four (24) hours to allow for absorption and refill the tank(s) to two (2) inches above the tank and riser connection if necessary. Measure water level. If there is no measurable loss for one (1) hour, the tank is considered watertight.